



# IECEX Certificate of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit [www.iecex.com](http://www.iecex.com)

Certificate No.: **IECEX QPS 19.0001X** Page 1 of 4 Certificate history:  
Status: **Current** Issue No: 2 Issue 1 (2020-03-24)  
Issue 0 (2019-04-03)  
Date of Issue: 2022-03-11  
Applicant: **Anton Paar GmbH**  
Anton-Paar-Strasse 20  
Graz, 8054  
**Austria**  
Equipment: **L-Com 5500 Series - Density and Sound Velocity Sensor**  
Optional accessory:  
Type of Protection: **d**  
Marking: **IECEX QPS 19.0001X**  
**Ex db IIB T4/T5 Gb**  
*See EQUIPMENT section for full marking details*

Approved for issue on behalf of the IECEx  
Certification Body:

**D. Adams P.Eng.**

Position:

**Manager, Hazardous Locations Department [Ex Equipment]**

Signature:  
(for printed version)

Date:  
(for printed version)

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting [www.iecex.com](http://www.iecex.com) or use of this QR Code.



Certificate issued by:

**QPS**  
**Evaluation Services Inc.**  
**81 Kelfield St**  
**Unit 8**  
**Toronto, Ontario M9W 5A3**  
**Canada**





# IECEX Certificate of Conformity

Certificate No.: **IECEX QPS 19.0001X**

Page 2 of 4

Date of issue: 2022-03-11

Issue No: 2

Manufacturer: **Anton Paar GmbH**  
Anton-Paar-Strasse 20  
Graz, 8054  
**Austria**

Manufacturing locations: **Anton Paar GmbH**  
Anton-Paar-Strasse 20  
Graz, 8054  
**Austria**

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEX Quality system requirements. This certificate is granted subject to the conditions as set out in IECEX Scheme Rules, IECEX 02 and Operational Documents as amended

#### STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

[IEC 60079-0:2017](#) Explosive atmospheres - Part 0: Equipment - General requirements  
Edition:7.0

[IEC 60079-1:2014-06](#) Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d"  
Edition:7.0

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

#### TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Reports:

[CA/QPS/ExTR19.0003/00](#)

[CA/QPS/ExTR19.0003/01](#)

[CA/QPS/ExTR19.0003/02](#)

Quality Assessment Report:

[DE/TPS/QAR14.0002/05](#)



# IECEX Certificate of Conformity

Certificate No.: **IECEX QPS 19.0001X**

Page 3 of 4

Date of issue: 2022-03-11

Issue No: 2

## EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

The L-Com 5500 Series Density and Sound Velocity Sensors are process measuring instruments that are used to measure the density and sound velocity values of liquids. The sensor consists of the encapsulated sensing element and a sensor board, which is connected to the sensing element with a feedthrough. The sensor board is connected to the process instrumentation controller (Pico 3000) or to an external evaluation unit. The Pico 3000 can be installed in the electronic housing of the sensor or in an optional remote operating housing (Pico 3000 RC). The Pico 3000 can be used with an optional HMI (Pico 3000 HMI).

The limitation of the ambient temperature for the sensor, the sensor with Pico 3000 and the sensor with Pico 3000 + Pico 3000 HMI is different.

L-Com 5500 HAS Ex d: Ta = -25 to 65 °C

L-Com 5500 HAS Ex d with Pico 3000: Ta = -25 to 55 °C

L-Com 5500 HAS Ex d with Pico 3000 and Pico 3000 HMI: Ta = -20 to 55 °C

Ratings: 24 Vdc ± 20%, max. 5 W (without Pico 3000) / 8 W (with Pico 3000).

The relationship between process media temperature is as follow:

- For Tp = -25°C to +95°C ⇒ T5 temperature class assignment;
- For Tp = -25°C to +125°C ⇒ T4 temperature class assignment.

## Model Nomenclature:

Model	Markings
<b>L-Com 5500 HAS Ex d</b> <b>L-Com 5500 HAS NPT Ex d</b>	Ex db IIB T4/T5 Gb Ta= -25°C to 65°C Tp= -25°C to 95°C(T5)/125°C(T4) Maximum process pressure: 50 bar
<b>L-Com 5500 HAS Ex d (with Pico 3000)</b> <b>L-Com 5500 HAS NPT Ex d (with Pico 3000)</b>	Ex db IIB T4/T5 Gb Ta= -25°C to +55°C Tp= -25°C to 95°C(T5)/125°C(T4) Maximum process pressure: 50 bar
<b>L-Com 5500 HAS Ex d (with Pico 3000 and HMI)</b> <b>L-Com 5500 HAS NPT Ex d (with Pico 3000 and HMI)</b>	Ex db IIB T4/T5 Gb Ta= -20°C to 55°C Tp= -25°C to 95°C(T5)/125°C(T4) Maximum process pressure: 50 bar

## SPECIFIC CONDITIONS OF USE: YES as shown below:

Density and Sound Velocity Sensor L-Com 5500 HAS Ex d is suitable for application at an extended ambient temperature range and such is having defined special conditions for safe use as follow:

1. For power cable, use only a cable whose thermal stability of its insulation is minimum 90°C.
2. For cable entrances use only already certified Ex d or Ex db cable glands suitable for application and rated for a minimum of 80°C.
3. Unused openings shall be closed by use of already certified Ex d or Ex db stopping plugs suitable for application.



# IECEX Certificate of Conformity

Certificate No.: **IECEX QPS 19.0001X**

Page 4 of 4

Date of issue: 2022-03-11

Issue No: 2

**DETAILS OF CERTIFICATE CHANGES (for issues 1 and above)**  
issue 2 - update to installation manual